

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171691, Building Permit - Residential

Address: 4717 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, September 07, 2017

Corrective Action Required

1 Misc

FRAMING:

-FRAME CS PF WALLS PER PLAN

**HAVE ENGINEER ADDRESS THIS. PLAN CALLS FOR A/4 CSPF WALL DETAIL

MECHANICAL:

-INSTALL INSULATION SHIELD FOR THE HEARTH FIREPLACE VENT AS REQUIRED PER IRC G2426.4 (IGFC 502.4). MAKE SURE THE SHIELD PROVIDE MIN. 1" CLEARANCE AROUND THE VENT, SEPARATING THE BLOWN-IN INSULATION FROM THE VENT

**OK TO INSULATE

Comments: