

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172778, Building Permit - Commercial

Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Friday, September 08, 2017

Partial Correction

1	Misc	UNDERGROUND RACEWAYS TO LIGHT POLES-OK
---	------	--

ALL PIERS OK TO POUR EXCEPT THE SHORT PIER AT EAST SIDE OF PARKING LOT AND THE SW LP PIER THAT NEEDS A GROUND ROD

Comments: