

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20172977, Building Permit - Commercial

Address: 520 NW MURRAY RD, Unit:CHRG, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Passed	Friday, September 08, 2017

<del>Underground Electrical Inspection - Commercial</del>	John Borns	Not Ready	Friday, September 08, 2017
-----------------------------------------------------------	------------	-----------	----------------------------

**Comments: OK TO COVER WHEN READY PVC CONDUIT TRENCHED & LAID FROM METER LOCATION TO THREE CHARGING STATION LOCATIONS. GROUND ROD WITH LEAD DRIVEN IN TRENCH BOTTOM.**