

Inspection Summary

Permit #: PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, September 08, 2017

Corrective Action Required

1 Misc

ROOFTOP:

- SUBMIT LIGHTNING PROTECTION SYSTEM CERT
- FINAL CLEANUP

Corrective Action Required

3 Misc

- RESOLVE FIRE DEPARTMENT ISSUES
- RESOLVE PUBLIC WORKS ISSUES
- RESOLVE PLANNING ISSUES

Comments: