

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171149, Building Permit - Commercial

Address: 1710 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Friday, September 08, 2017

GAS PIPING PRESSURE TEST LOST NO PRESSURE OVER >60 MINUTES AT ~28 PSI.

YET TO BE COMPLETED:

- CHECK AND CORRECT PROOFTOP PIPE SUPPORT INTERVALS PER IFGC**
- COMPLETE CLAMPS AT BLOCKS**