

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Friday, September 08, 2017

Partial Correction

1 Misc

TRENCHED FEEDER PIPE FROM SITE DISTRIBUTION LINE TO BLDG "A" OK TO COVER WHEN READY. PRESSURE TEST HALD STEADY AT >100 PSI FOR > 20 MINUTES. NO ISSUES ON VISUAL INSPECTION.

Partial Correction

2 Misc

INTERIOR GAS PIPING PRESSURE TEST HELD STEADY FOR >60 MINUTES AT ~30 PSI. PASSED.

Comments: