

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Failed	Friday, September 08, 2017

Corrective Action Required

1 Misc

PRELIMINARY FRAMING INSPECTION:

4TH FLOOR: ISSUES IDENTIFIED

Corrective Action Required

2 Misc

FLUSH NAIL ALL ROOF SHEATHING. NOT APPROVED.

Comments: