

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170499, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Failed	Monday, September 11, 2017

Corrective Action Required

1	Misc	EXPANSION TANK REQUIRED AT WATER HEATER
---	------	---

Corrective Action Required

2	Misc	ENSURE EF-1s ARE NOT FOR NAIL STATIONS
---	------	--

Comments: