

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

September 11, 2017

CRAIG LUEBBERT - CL ARCHITECTURE
396 SW WINTERGARDEN
LEES SUMMIT, MO 64081

Permit No: PRCOM20171543
Project Title: BOISE CASCADE
Project Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063
Parcel Number: 61320010200000000
Location: SEC 6 TWN SHP 47 RNG 31 PT OF THE NE 1/4 OF NW 1/4, BEG 297.37' W OF NE COR & 90'
STO TRU PT OF BEG TH S 160' TH E 297 FT TH S 70' MOL TH W 70' TH S 727' MOL TH W 329'
MOL TH N ALG E
Type of Work: NEW COMMERCIAL
Occupancy Group:
Description: NEW OFFICE BUILDING TO REPLACE BUILDING DESTROYED IN STORM

**planning dept reqd at final to verify screening

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

If not existing, address shall be readable from the roadway (Chipman Road)

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide one (5 pound) 2A-10BC fire extinguisher to be mounted on a normal path of travel close to an exit.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

CODES ADMINISTRATION

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

2. There is an open demolition permit for this property.

Action required: Comment is for informational purposes. No type of occupancy to be granted until after the demolition permit has been closed.

4. 2011 NEC 334.80 Ampacity. The ampacity of Types NM, NMC, and NMS cable shall be determined in accordance with 310.15. The allowable ampacity shall not exceed that of a 60degC (140degF) rated conductor. The 90degC (194degF) rating shall be permitted to be used for ampacity adjustment and correction calculations, provided the final derated ampacity does not exceed that of a 60degC (140degF) rated conductor. The ampacity of Types NM, NMC, and NMS cable installed in cable tray shall be determined in accordance with 395.80(A). (see code for additional requirements)

Action required: Comment is for informational purposes. Wiring in attic must be derated for temperature. To be field verified.

7. Copies of the engineered truss package were not provided at the time of permit application.

Action required: Provide roof truss package or request deferral.
9/5/17 - deferred per request

8. 2012 IBC 1012.6 – Handrail extensions. Handrails shall return to a wall, guard or the walking surface or shall be continuous to the handrail of an adjacent stair flight or ramp run. Where handrails are not continuous between flights, the handrails shall extend horizontally at least 12 inches beyond the top riser and continuous to slope for the depth of one tread beyond the bottom riser. At ramps where handrails are not continuous between runs, the handrails shall extend horizontally above the landing 12 inches minimum beyond the top and bottom of ramp runs. The extensions of handrails shall be in the same direction of the stair flights at stairways and the ramp runs at ramps. (See code section for possible exceptions.)

Action required: Modify detail 5/A3.0 to demonstrate compliance.
9/5/17 - handrails must return to a wall or newel post.

11. Rooms 102 & 105 do not have return air.

Action required: Provide return air from rooms 102 & 105.
9/5/17 - return air shown to be "booted" but with no other installation direction. If the boot transfers to plenum then the gas fired appliances will not be allowed.

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)
No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

CODES ADMINISTRATION

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.