

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20172692, Building Permit - Commercial

Address: 1215 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Tuesday, September 12, 2017

### Corrective Action Required

1	Misc	CORRECTION REQUIRED: COMPLETE REMOVAL OF ELECTRICAL RACEWAY IN RESTROOM AND INSTALL FRAME HEADER
---	------	--

**\*\*NOTE: INSTALL FIRE SPRINKLER FOR EACH SPACE; REMOVE DEAD BOLT LOCK REAR EXIT DOOR; WILL NEED AN ABOVE CEILING INSPECTION. HAVE LADDER AVAILABLE**

### Comments: