

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170810, Building Permit - Residential

Address: 1832 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Dale Carter	Passed	Thursday, September 14, 2017

Gas Service Inspection - Residential	Dale Carter	Passed	Thursday, September 14, 2017
---	-------------	--------	------------------------------

All Rough Inspection - Residential	Dale Carter	Failed	Thursday, September 14, 2017
---	-------------	--------	------------------------------

Corrective Action Required

1	Misc	2. BSMT: Firestop at ends of ceiling furr-out. (*still missing near top of stairs and near shower) 4. 1st FLR: Firestop tops of DWV chases at rear of Living Room & Garage.
---	------	--

Gas Piping Inspection - Residential	Dale Carter	Passed	Thursday, September 14, 2017
--	-------------	--------	------------------------------

Comments: