

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172941, Building Permit - Commercial

Address: 332 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Mechanical Inspection - Commercial	John Borns	Passed	Thursday, September 14, 2017

Comments: SMALL HVAC UNIT REPLACEMENT. WAIVED REQUIREMENTS FOR GUARD AT ROOF EDGE AND ELECTRICAL RECEPTACLE WITHIN 25'. CLOSE PERMIT.