

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170985, Building Permit - Commercial

Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Thursday, September 14, 2017

Comments: PRESSURE TEST ON GAS PIPING HELD STEADY AT 19.6 PSI FOR >20 MINUTES; OK FOR USE. ONE NEW STEEL PIPE STUB WHERE BRANCH WAS ELIMINATED NEEDS TO BE PAINTED.