

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20160868, Building Permit - Residential

Address: 257 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Friday, September 15, 2017

Corrective Action Required

1	Misc	-REAR DOOR SECURITY SCREWS -CEDAR POST COVERED PORCH NOT SUITABLE FOR GROUND CONTACT -MAX FUSE FOR AC UNIT IS 40 AMP
---	------	--

Driveway Inspection	Mike Copeland	Passed	Friday, September 15, 2017
----------------------------	---------------	--------	----------------------------

Corrective Action Required

1	PW-Misc	Pass forms
---	---------	------------

Comments: