

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170985, Building Permit - Commercial

Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, September 15, 2017

Partial Correction

3 Misc

**ALL SPACES OK FOR USE EXCEPT IT ROOM & TEMPORARY
INVENTORY ROOM. SEE ISSUE AT RESTROOMS.**

Corrective Action Required

4 Misc

VERTICAL GRAB BARS AT RESTROOMS <39" FROM FINISHED BACK
WALLS

Comments: