



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20172659	Date:	September 18, 2017
Project Title:	TOTAL BODY FITNESS	Applicant:	
Location:	3680 NE AKIN DR, Unit:128, LEES SUMMIT, MO 64064	ALPHA FIRE PROTECTION LLC P.O. Box 50 INDEPENDENCE, MO 64051	
Type of Work:			
Occupancy Group:	A-4		
Description:	TENANT EXPANSION INTO ADJACENT SPACE	Primary:	(816) 257-2260
Construction Type:	Type IIB (Unprotected)		
Map Page:	175M		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED: (verified at inspection)

The existing fire sprinkler system shall be current with all required service/maintenance. A current service tag shall be posted on the systems riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.