

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial

Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, September 18, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:
NORTH STAIRWELL:
BASEMENT LEVEL 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; **2ND LAYER AT WELL FACE;**

4TH FLOOR: [1ST LAYER @ WELL FACE;

SOUTH STAIRWELL:

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; **[2ND LAYER AT WELL FACE];**

4TH FLOOR: [1ST LAYER @ WELL FACE];

Partial Correction
2 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT ELEVATOR:
2ND FLOOR: 1ST & 2ND LAYERS PRE-ROCK;
3RD FLOOR: 1ST & 2ND LAYER PRE-ROCK AT JOIST BAYS;

Partial Correction
3 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT SHOWERS/TUBS AT:
4TH FLOOR
3RD FLOOR
2ND FLOOR
1ST FLOOR

All Rough Inspection - Commercial

John Borns

Partial

Monday, September 18, 2017

Partial Correction
1 Misc

OK TO INSTALL PRE-ROCK INSULATION AND GWB WHEN READY AT SHOWER PRE-ROCK AREAS AT:
4TH FLOOR UNITS;
3RD FLOOR UNITS;
2ND FLOOR UNITS AFTER FIREBLOCKING COMPLETED;
1ST FLOOR UNITS AFTER FIREBLOCKING COMPLETED;;

Partial Correction
2 Misc

OK TO COVER WHEN READY FRAMING & ENCLOSED SYSTEMS AT:
STAIR TOWERS AND ELEVATOR SHAFT ABOVE 4TH FLOOR; **[SW STAIRWELL AT BASEMENT];**

Comments: