

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171730, Building Permit - Residential

Address: 4222 NE PARK SPRINGS CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Khanh Nguyen	Passed	Monday, September 18, 2017

Electrical Service Inspection - Residential	Khanh Nguyen	Passed	Monday, September 18, 2017
--	--------------	--------	----------------------------

All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, September 18, 2017
---	--------------	--------	----------------------------

Corrective Action Required

1 Misc

****REESTABLISH EROSION CONTROL**

FRAMING:

-FIREPLACE WALL: BRACE LVL BEAM END FROM ROTATION;

INSTALL 3 STUDS UNDER LVL BEAM

-FIREBLOCKING: FB FIREPLACE SPACE (GAP); FB BASEMENT WALL SPACE PER CODE

-TOE NAIL ALL BASEMENT JOISTS TO SILL PLATE W/ 3-8D OR EQUIVALENCE

ELECTRICAL:

-PROTECT WIRING THROUGHOUT (AT GARAGE CORNER NEAR DRYER; REAR DINING; IN MASTER BED BOTH NM AND SE CABLE; ETC)

*****OK TO INSULATE**

Comments: