



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

September 19, 2017

HEREFORD DOOLEY ARCHITECTS
1720 WEST END AVENUE, SUITE 130
NASHVILLE, TN 37203

Permit No: PRCOM20173051
Project Title: LEE'S SUMMIT MEDICAL CENTER - HCA MEDICAL OFFICE BUILDING
Project Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 60420990900000000
Location: HCA MIDWEST, LOTS 1A & 1B---LOT 1A
Type of Work: NEW SHELL BUILDING
Occupancy Group: BUSINESS
Description: 3 STORY SHELL BUILDING FOR FUTURE MEDICAL TENANTS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED:(information purposes)

Have the fire alarm system contractor provide shop drawings for approval of the fire alarm system to be installed.

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7

mm).

ACTION REQUIRED:(verified at inspection)

Address of 2100 shall be readable from the roadway (Blue Parkway)

3. 2012 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

ACTION REQUIRED:(information purposes)

Knox boxes can be obtained online at knoxbox.com

Provide a knox box for building accesss. Knox box shall be mounted on the exterior of the building by the sprinkler room access door.

Provide a knox box to be mounted on the interior by the elevator bank.

506.1.2 Key boxes for nonstandardized fire service elevator keys.

Key boxes provided for nonstandardized fire service elevator keys shall comply with Section 506.1 and all of the following:

1. The key box shall be compatible with an existing rapid entry key box system in use in the jurisdiction and approved by the fire code official.
2. The front cover shall be permanently labeled with the words "Fire Department Use Only—Elevator Keys."
3. The key box shall be mounted at each elevator bank at the lobby nearest to the lowest level of fire department access.
4. The key box shall be mounted 5 feet 6 inches (1676 mm) above the finished floor to the right side of the elevator bank.
5. Contents of the key box are limited to fire service elevator keys. Additional elevator access tools, keys and information pertinent to emergency planning or elevator access shall be permitted when authorized by the fire code official.
6. In buildings with two or more elevator banks, a single key box shall be permitted to be used when such elevator banks are separated by not more than 30 feet (9144 mm). Additional key boxes shall be provided for each individual elevator or elevator bank separated by more than 30 feet (9144 mm).

4. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

The FDC shall be a 4" Storz fitting with a 30 degree elbow not a 2 1/2" siemens. Riser drains shall be piped to the exterior not floor drains. Have the Fire Sprinkler System contractor provide shop drawings for approval of the fire sprinkler system to be installed.

5. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Field tests and acceptance testing of the fire sprinkler and fire alarm systems will be required prior to the final occupancy inspection. To schedule a test contact the fire department at (816)969-1300)

6. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(information purposes)

Provide and mount fire extinguishers according to the plans.

7. Stairways

ACTION REQUIRED: Each floor level shall be posted at the door of each stairway landing.

8. Door operations

ACTION REQUIRED:No key locks on the egress side of an exit.

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

9. Evacuation plans

ACTION REQUIRED:(information purposes)

Evacuation plans (egress paths) shall be posted in the corridors

404.3 Contents.

Fire safety and evacuation plan contents shall be in accordance with Sections 404.3.1 and 404.3.2.

10. FDC access

ACTION REQUIRED:Stripe off the parking space directly in front of the FDC pedestal for no Parking and clear access for fire operations.

503.3 Marking.

Where required by the fire code official, approved signs or other approved notices or markings that include the words NO PARKING—FIRE LANE shall be provided for fire apparatus access roads to identify such roads or prohibit the obstruction thereof. The means by which fire lanes are designated shall be maintained in a clean and legible condition at all times and be replaced or repaired when necessary to provide adequate visibility.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.