

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20160939, Building Permit - Commercial

Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Tuesday, September 19, 2017

Partial Correction

1 Misc

UNDERGROUND ELECTRICAL OK BELOW:  
-UE FOR EXTERIOR LP LIGHTS AND POWER-OK

LIGHT POLES PIERS:  
-6 LP PIERS OK TO POUR

SIDEWALK LIGHTS UG&PIERS -OK

**\*\*NEED TO SUBMIT PLAN OF OMISSION OF THE FRONT YARD LP**

**Comments:**