

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172464, Building Permit - Residential

Address: 2093 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822095 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822097 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822091 SW TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, September 19, 2017

Corrective Action Required

1	Misc	2091 complete plumb over front door. -connect bath fans firestop 1st floor bath and laundry 2093 over bored studs at 2x6 wall, t up stud or replace. (same on 95) Firestop penetrations throughout 4 units. Nail corners studs. connect bath fans -complete elect panel, uffer. -firestop heat ducts through floor center 2 units.
---	------	---

Rated Assembly Inspection	Mark Harding	Passed	Tuesday, September 19, 2017
----------------------------------	--------------	--------	-----------------------------

Electrical Service Inspection - Residential	Mark Harding	Failed	Tuesday, September 19, 2017
--	--------------	--------	-----------------------------

Comments:

