

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170431, Building Permit - Residential

Address: 2222 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822224 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822226 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822220 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Tuesday, September 19, 2017

Corrective Action Required

1	Misc	<ul style="list-style-type: none">- seal garage hose bib penetrations- cap plumbing at bsmt floor-anti syphon bsmt hose bib-tempered windows rear door 1st floor- seal angle wall in garage. <p>front porch handrail north end sod, erosion control etc.</p>
---	------	--

Comments: