Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly John Borns Partial Tuesday, September 19, 2017 **Inspection**

Partial Correction

1 Misc OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X

MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:

NORTH STAIRWELL:

BASEMENT LEVEL 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK

AT JOIST BAYS

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT

JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST

BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; 2ND LAYER AT WELL

FACE;

4TH FLOOR: 1ST LAYER @ WELL FACE; [2ND LAYER AT WELL

FACE;

SOUTH STAIRWELL:

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT

JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST

BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; 2ND LAYER AT WELL

FACE;

4TH FLOOR: 1ST LAYER @ WELL FACE; [2ND LAYER @ WELL FACE;

Partial Correction

2 Misc OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X

MOLD-TOUGH GWB RATED ASSEMBLIES AT ELEVATOR:

2ND FLOOR: 1ST & 2ND LAYERS PRE-ROCK;

3RD FLOOR: 1ST & 2ND LAYER PRE-ROCK AT JOIST BAYS;

[1ST LAYER WELL FACE FULL HEIGHT + 1ST LAYER AT CEILING;

Partial Correction

3 Misc OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT

SHOWERS/TUBS AT:

4TH FLOOR 3RD FLOOR 2ND FLOOR 1ST FLOOR

All Rough Inspection - John Borns

Partial

Tuesday, September 19, 2017

Commercial

Partial Correction

1 Misc OK TO INSTALL PRE-ROCK INSULATION AND GWB WHEN READY

AT SHOWER PRE-ROCK AREAS AT:

4TH FLOOR UNITS; 3RD FLOOR UNITS;

2ND FLOOR UNITS AFTER FIREBLOCKING COMPLETED; 1ST FLOOR UNITS AFTER FIREBLOCKING COMPLETED;;

Partial Correction

3 Misc OK TO COVER WHEN READY CEILING & WALL FRAMING &

ENCLOSED SYSTEMS AT:

[4TH FLOOR ALL UNITS/SPACES

Comments: