

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171730, Building Permit - Residential

Address: 4222 NE PARK SPRINGS CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, September 20, 2017

Corrective Action Required

1 Misc

**REESTABLISH EROSION CONTROL

-TOE NAIL ALL BASEMENT JOISTS TO SILL PLATE W/ 3-8D OR EQUIVALENC

***OK TO INSULATE

Comments: