

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162134, Public Works Infrastructure Permit - Commercial
HT SOLUTIONS

Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Storm - Inlets Clean	Brice Lawson	Passed	Wednesday, September 20, 2017

Resolved

- 1 Brice Lawson 02/15/2017 1:46 PM
Remove esc devices from the basin at the southwest corner of the building and from the drain close to the down spouts on the east side of the building.

Remove the lift cable on the outlet structure lid.

Brice Lawson 09/20/2017 10:34 AM
Items listed above have been resolved

Comments: