

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171226, Building Permit - Residential

Address: 611 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Borns	Passed	Wednesday, September 20, 2017
Electrical Service Inspection - Residential	John Borns	Failed	Wednesday, September 20, 2017

Corrective Action Required

1	Misc	NEC 250.92B; IRC E3510.1. BONDING OF SERVICE ENCLOSURES & EQUIPMENT: REMAINING KNOCKOUTS PREVENT NIPPLE FROM PROVIDING CERTAIN BONDING OF METER ENCLOSURE AND DISCONNECT ENCLOSURE.
---	------	---

BONDING CONTACT NOT EXTENDED TO METER ENCLOSURE.

Comments: