

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173078, Building Permit - Commercial
Address: 793 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|-----------|----------------------------------|
| Electrical Service Inspection - Commercial | John Borns | Not Ready | Wednesday, September 20, 2017 |

Corrective Action Required

1 Misc

UNDERGROUND WIRING WAS NOT REQUESTED FOR INSPECTION
-- NOT APPROVED.

Comments: