

Temporary Certificate of Occupancy

Permit #: PRRES20162317
Address: 1317 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Thursday, September 21, 2017
Inspected By: Khanh Nguyen
Expiration Date: 10/20/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, September 21, 2017

Corrective Action Required:

1	Misc	-UN-RESOLVED ISSUE FROM ALL ROUGH INSPECTION OVER MASTER SHOWER. EXPOSE FOR INSPECTION. **REQUIRE VERIFICATION THAT THE SUBFLOOR SUPPORT UNDER THE SHOWER IS COMPLETED
---	------	---