

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit: PRRES20171814, Building Permit - Residential

Address: 4713 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------------|------------|--------------------|--------------------|
| Driveway Inspection | Bart Reese | Passed | September 21, 2017 |
| Sidewalk Inspection | Bart Reese | Passed | September 21, 2017 |
| Erosion/Sediment Control (ESC) | Bart Reese | Abatement required | September 21, 2017 |

Corrective Action Required

ESC device(s) needed on NE corner of the property.

Comments: ESC is needed on NE corner of property. Street and curb (entire curb) need to be swept clean.