

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172978, Building Permit - Commercial

Address: 601 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mike Copeland	Passed	Thursday, September 21, 2017

**Comments: CONDUITS FROM GEAR TO CHARGING STATIONS AND TWO DRIVEN GROUND RODS
APPROVED.**