

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173078, Building Permit - Commercial  
Address: 793 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Friday, September 22, 2017

<b>Final Electrical Inspection - Commercial</b>	John Borns	Passed	Friday, September 22, 2017
---	------------	--------	----------------------------

<del><b>Electrical Service Inspection - Commercial</b></del>	<del>John Borns</del>	<del>Not Ready</del>	<del>Friday, September 22, 2017</del>
--	-----------------------	----------------------	---------------------------------------

### Corrective Action Required

<del>1</del>	<del>Misc</del>	<del>UNDERGROUND WIRING WAS NOT REQUESTED FOR INSPECTION -- NOT APPROVED.</del>
--------------	-----------------	---

~~21-SEPT-CALLED JASON TWICE BUT RECEIVED NO ANSWER. NO  
ACCESS PROVIDED TO THE INTERIOR OF THE SERVICE  
DISCONNECT FOR INSPECTION.~~

**Comments: RELEASE PEDESTAL ELECTRICAL SERVICE. CLOSE PERMIT.**