

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171187, Building Permit - Residential

Address: 3400 SW LOIS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Friday, September 22, 2017

Corrective Action Required

1	Misc	1. Master bedroom, plans show exterior wall to be closet, alteration made and window is installed at north wall. Plan identifies this wall as braced wall line. Cannot have a window in a braced wall line. Have engineer address.
---	------	--

Gas Service Inspection - Residential	Mike Copeland	Passed	Friday, September 22, 2017
---	---------------	--------	----------------------------

Comments: