

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173026, Building Permit - Commercial

Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Failed	Friday, September 22, 2017

Corrective Action Required

1	Misc	FOOTING REINFORCING NOT PER DRAWING.
---	------	---

Footing Inspection - Commercial	John Borns	Passed	Friday, September 22, 2017
---------------------------------	------------	--------	----------------------------

Comments: DOCUMENTATION TO BE PROVIDED ON REINFORCING MODIFICATIONS (4 BARS E/W IN LIEU OF 5) AT CORNER FOOTINGS. SUPPORT RE-BAR DRIVEN INTO BOTTOM OF EXCAVATIONS ALLOWED THIS INSTANCE TO FACILITATE POUR BEFORE RAIN. ENSURE MINIMUM 3" RE-BAR COVERAGE AT BOTTOMS AND BANKS AT TIME OF POUR. OK TO POUR WHEN READY.