Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172339, Building Permit - Commercial Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection John Borns Partial Monday, September 25, 2017

Partial Correction

1 Misc OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING +

ENCLOSED M/E/P SYSTEMS AT: FALSE WALL AT PERIMETER

EXCEPT SOUTH WALL PARTIAL PENDING

CREATION/MODIFICATION OF OPENINGS; EAST DEMISING WALL

EXCEPT NORTH 10' NOT YET FRAMED;

Partial Correction

2 Misc LOCKER ROOMS, MENS, WOMANS, SHOWERS, JANITOR

ROOMS;

Comments: RE-SCREW ANY RATED WALL GWB TAPED BEFORE RATED ASSEMBLY INSPECTION. SPRINKLER CONTRACTOR PROVIDE CODE DOCUMENTATION TO JUSTIFY USE OF SMALL-DIAMETER PIPE HORIZONTAL SUPPORTS FOR SPRINKLER PIPING.