

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171228, Building Permit - Residential

Address: 617 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081619 NW LILAC PL, LEES SUMMIT, MO
64081615 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	John Borns	Passed	Monday, September 25, 2017

Rated Assembly Inspection	John Borns	Partial	Monday, September 25, 2017
--------------------------------------	------------	---------	----------------------------

Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT RATED WALLS :
1ST LAYER AT ALL(3) UNIT SEPARATION WALLS;

Comments: OK TO COVER WHEN READY DRAIN PIPING AT THREE GARAGES.