



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20170788	Date:	September 25, 2017
Project Title:	LBP V-A	Applicant:	
Location:	2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		ADVANTAGE FIRE PROTECTION SYSTEMS INC 404 B NW 11TH ST BLUE SPRINGS, MO 64015
Type of Work:			
Occupancy Group:	N/A		
Description:	NEW SHELL BUILDING FOR FUTURE WAREHOUSE	Primary:	(816) 224-3400
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Field test and acceptance testing of the system will be required prior to the final occupancy inspection.

Contact the fire department to schedule testing.

(816)969-1300

INFORMATIONAL PURPOSES: The numeric address is incorrect on the plans, numeric address on the plans is shown as 2700. It should 2900, no resubmittal needed

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.