Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Rough Framing Inspection - Commercial	Dale Carter	Partial	Monday, September 25, 2017	
Corrective Action Required				
1 Misc	PRELIN	/INARY FRAMING INSPECT	ION:	
	4TH FL	OOR: ISSUES IDENTIFIED		
Partial Correction				
2 Misc	ROOF	ROOF SHEATHING OK TO COVER WHEN READY AFTER BUTT JOINT		
	GAPS A	AT SOUTH END ARE ELIMIN	ATED BY REPLACMENT OF ONE	
	OR MC	DRE 16" SECTIONS OF GAPP	ED SHEETS.	
Partial Correction				
3 Misc		 Exterior sheathing nailin and nailing inspected. OK 	g inspected. Garage portal to cover.	

Comments: