



LEE'S SUMMIT MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

| | | | |
|--|---|------------|---|
| Permit No: | PRCOM20171531 | Date: | September 25, 2017 |
| Project Title: | NAILTOPIA | Applicant: | |
| Location: | 3500 SW MARKET ST, LEES SUMMIT, MO 64082 | | ADVANTAGE FIRE PROTECTION SYSTEMS INC 404 B NW 11TH ST BLUE SPRINGS, MO 64015 |
| Type of Work: | | | |
| Occupancy Group: | | | |
| Description: | TENANT FINISH FOR NAIL SALON | Primary: | (816) 224-3400 |
| **no inspections until mechanical contractor is listed | | | |
| Construction Type: | Type IIIB (Unprotected) | | |
| Map Page: | 215B | | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(verified at inspection)

The existing fire sprinkler riser shall be current with all required service and maintenance. A current service tag shall be posted on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.