

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171689, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, September 25, 2017

Partial Correction

1 Misc

OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT
FIRE-RATED WALLS AT:

**TOP-OUT ONLY AT: 1A212 W WALL AT DOOR #212.3; 218 N, W,
S WALLS: 258 W WALL; 260 W WALL; 261 W WALL; 262.1 N, W
WALLS; 262.2 W WALL;**

Comments: