



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

September 25, 2017

[K] WARMAN ARCHITECTS
1828 SWIFT, SUITE 101
NORTH KANSAS CITY, MO 64116

Permit No: PRCOM20173153
Project Title: SCOOTER'S COFFEE KIOSK
Project Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082
Parcel Number: 70920160200000000
Location: RAINTREE LAKE VILLAGE LOTS 1-6 & TR A---LOT 4
Type of Work: NEW COMMERCIAL
Occupancy Group:
Description: DRIVE-THRU COFFEE SHOP WITH NOT IN STORE SERVICE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: Numeric address shall be readable from the addressed roadway

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide one 2A-10BC fire extinguisher. Fire extinguisher to be mounted close to the exit.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.