

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial

Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, September 25, 2017

Partial Correction

1

Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:
NORTH STAIRWELL:
BASEMENT LEVEL 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; 2ND LAYER AT WELL FACE;

4TH FLOOR: 1ST LAYER @ WELL FACE; 2ND LAYER AT WELL FACE;

SOUTH STAIRWELL:

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; 2ND LAYER AT WELL FACE;

4TH FLOOR: 1ST LAYER @ WELL FACE; 2ND LAYER @ WELL FACE;

Partial Correction
2 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT ELEVATOR:

2ND FLOOR: 1ST & 2ND LAYERS PRE-ROCK;

3RD FLOOR: 1ST & 2ND LAYER PRE-ROCK AT JOIST BAYS;

1ST LAYER WELL FACE FULL HEIGHT + 1ST LAYER AT CEILING; 2ND LAYER WELL FACE FULL HEIGHT + 2ND LAYER AT CEILING; 3RD LAYER AT CEILING + HAT CHANNEL; **[4TH LAYER AT CEILING OK TO TAPE, MUD AND FIRE-STOP**

Partial Correction
3 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT SHOWERS/TUBS AT:

4TH FLOOR

3RD FLOOR

2ND FLOOR

1ST FLOOR

Partial Correction
4 Misc

2ND FLOOR ELECTRICAL CLOSET: OK TO COVER FIRST LAYER GWB; [2ND LAYER ADJACENT TO ELEVATOR;

BASEMENT IT ROOM: ONE LAYER GWB; **[2ND LAYER GWB**

Comments: