

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161767, Building Permit - Commercial

Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, September 25, 2017

### Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT:

SOUTH STAIRWELL:

1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;

2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;

3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; **[2ND LAYER PRE-ROCK ONLY;**

NORTH STAIRWELL:

1ST FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; 2ND LAYER AT WELL FACE AND PRE-ROCK;

2ND FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; PRE-ROCK ONLY 2ND LAYER; 2ND LAYER WELL FACE;

3RD FLOOR: 1ST LAYER AT WELL FACE AND PRE-ROCK; **[2ND LAYER PRE-ROCK ONLY;**

### Partial Correction

2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT ELEVATOR

1ST FLOOR: 1ST LAYER PRE-ROCK; 2ND LAYER PRE-ROCK;

2ND FLOOR: 1ST LAYER PRE-ROCK; PRE-ROCK 2ND LAYER;

3RD FLOOR: 1ST LAYER PRE-ROCK; **[2ND LAYER PRE-ROCK;**

**Comments:**