

**CODES ADMINISTRATION**

**PLAN REVIEW CONDITIONS**

September 25, 2017

[K] WARMAN ARCHITECTS  
1828 SWIFT, SUITE 101  
NORTH KANSAS CITY, MO 64116

Permit No: PRCOM20173153  
Project Title: SCOOTER'S COFFEE KIOSK  
Project Address: 805 SW M 150 HWY, LEES SUMMIT, MO 64082  
Parcel Number: 70920160200000000  
Location: RAINTREE LAKE VILLAGE LOTS 1-6 & TR A---LOT 4  
Type of Work: NEW COMMERCIAL  
Occupancy Group:  
Description: DRIVE-THRU COFFEE SHOP WITH NOT IN STORE SERVICE

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

2. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

---

**CODES ADMINISTRATION**

2. The building permit for this project can not be issued until the Codes Administration Department has received the approved Final Development Plan from the Planning and Development Department.

Action required: Comment is for informational purposes.

3. All plans submitted for review on or after January 1, 2014 shall be designed to the requirements of the 2012 International Building Code, 2012 International Mechanical Code, 2012 International Plumbing Code, 2012 International Fuel Gas Code, 2012 International Fire Code, 2011 National Electric Code and the ANSI A117.1-2009 as amended and adopted by the City of Lee's Summit.

Action required: Revise code analysis to show correct year of ICC/ANSI. (2009)

4. A code analysis shall be provided which includes but is not limited to occupancy type, occupant load, construction type, actual area, height and floors, allowable area, height and floors, and the codes to which the project is designed.

Action required: Revise code analysis to show correct occupancy which is B.

5. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is for informational purposes.

6. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

7. 2012 IPC 708.3.2 Building sewers. Building sewers shall be provided with cleanouts located not more than 100 feet apart measured from the upstream entrance of the cleanout. For building sewers 8 inches and larger, manholes shall be provided and located not more than 200 feet from the junction of the building drain and building sewer, at each change in direction and at intervals of not more than 400 feet apart. Manholes and manhole covers shall be of an approved type.

Action required: Additional cleanout required as to not exceed the 100' limit.

8. Clarification required.

Action required: Water meter is noted as 3/4". Is it your intention to use a full 3/4" meter? (\$6,047.93) Or, the standard residential size of 5/8"x3/4" meter? (\$3,774.83)

**Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: Numeric address shall be readable from the addressed roadway

---

**CODES ADMINISTRATION**

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

Provide one 2A-10BC fire extinguisher. Fire extinguisher to be mounted close to the exit.

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***