



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

September 26, 2017

John Wisniewski Architect, LLC  
4320 SE Furlong Dr.  
Lee's Summit, MO 64082

Permit No: PRCOM20173173  
Project Title: SUMMIT BANK OF KANSAS CITY  
Project Address: 1150 NE DOUGLAS ST, LEES SUMMIT, MO 64086  
Parcel Number: 52910140100000000  
Location: DOUGLAS STATION COMMERCIAL PARK LOTS 1-10 & TR A---LOT 2 (EX PT IN ROW)  
Type of Work: CHANGE OF TENANT  
Occupancy Group: BUSINESS  
Description: INTERIOR ALTERATIONS TO EXISTING BUILDING AND ALTERATION TO EXISTING DRIVE-THRU CANOPY

\*\*invite police to final - Officers Carmen Spaeth and Scott Doumitt

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

#### 2. Section 7.330. CPTED Review Requirement.

All development applications shall be subject to CPTED review and recommendations. The application of CPTED concepts and strategies is site specific and the level of review shall be determined on a case by case basis. Some requests during development review will require mandatory compliance. Others will be strongly encouraged but compliance will be voluntary. Mandatory compliance elements will be addressed in Article 9 "Uses with Conditions".

Section 7.340. CPTED Uses Specified The following uses have been classified as "Uses with Conditions" per Article 9 of this Chapter, having been determined with a tendency toward an increased risk of crime,. Specific conditions for such uses are found in Article 9 and shall be required to be met prior to receiving any zoning approval, business license or approval to occupy any commercial space.

1. Bank/Financial Services

2. Bank Drive-Thru Facility
3. Check Cashing and Payday Loan Business
4. Convenience Store (C-Store)
5. Financial Services with Drive-up Window or Drive-Thru Facility
6. Pawn Shop
7. Title Loan Business, if performing on site cash transactions with \$500 or more in cash on hand
8. Unattended self-serve gas pumps
9. Unsecured Loan Business 10. Other similar uses shall meet the same standards as the above

Action required: Submit drawings or detailed report/spec to demonstrate compliance. A separate review for CPTED requirements must be performed. Permit will not be issued until CPTED review is approved.

3. All plans submitted for review on or after January 1, 2014 shall be designed to the requirements of the 2012 International Building Code, 2012 International Mechanical Code, 2012 International Plumbing Code, 2012 International Fuel Gas Code, 2012 International Fire Code, 2011 National Electric Code and the ANSI A117.1-2009 as amended and adopted by the City of Lee's Summit.

Action required: Modify code analysis to reflect current codes. All additions, alterations, etc. are to be designed, built, and inspected by the currently adopted codes.

4. ICC A117.1-2009 Section 404.2.3.2 Swinging Doors. Swinging doors shall have maneuvering clearances complying with Table 404.2.3.2.

Action required: Modify design to provide the minimum 18" clearance at the latch side of doors #5 & #6.

5. 2012 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: Modify design to provide at least 36" of accessible counter (maximum 36" high) at relocated teller stations.

7. 2012 IBC 1210.2.2 – Walls and partitions. Walls and partitions with 2 feet of service sinks, urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of not less than 4 feet above the floor, and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. (See code section for possible exceptions.)

Action required: Specify compliant wall finishes at restrooms. If paint is used it must be epoxy based.

#### **Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

The numeric address shall be readable from the addressed roadway (Douglas)

2. 2012 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be

along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

**ACTION REQUIRED:**

The mechanical room is not a conspicuous location, readily available location, on a normal path of travel. Three fire extinguishers are not required for the square footage of this business. relocate the extinguisher or discontinue it.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***