

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential  
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Sanitary Sewer Construction Inspection	Brice Lawson	Partial	Tuesday, September 26, 2017

Informational

- 1 Brice Lawson 09/26/2017 11:49 AM  
Redford has installed the 2nd barrell section for MH B-2. They have installed the 12" SDR 26 sewer pipe from MH B-2 up to approx. STA. 4+59. The 12" pipe that was not covered was being bedded in clean gravel. The wye fittings and anodes have been installed for lots 72 and 78.

Comments: