

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161760, Building Permit - Commercial

Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Partial	Tuesday, September 26, 2017

Partial Correction

1 Misc

POOL SHELL RE-BAR FOUND TO BE BONDED AT PERIMETER WITH LEADS TO ABOVE POUR ELEVATION. JUMPER FROM SHELL STEEL TO OUTDOOR LOUNGE SLAB RE-BAR MAT.

Partial Correction

2 Misc

POOL DECK RE-BAR BONDING APPROVED.

Comments: