

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE-Fire Line Construction Inspection	Steve Robbins	Partial	Tuesday, September 26, 2017

Informational

- 1 This morning Winwater did a water tap on the 8" main for the 6" fire line. Gene Williams approved this water tap. The contractor did a pressure test. . The bore was done last week with the 6" fire line going under the road. This afternoon they will connect the pipe to the valve that was installed next to the tap. The gate valve has been installed next to the tap with c900 pipe.I also spoke with the water dept. this morning and they agreed they can do a 2" tap off the fire line and the contractor will install copper up to the meter.Steve Robbins 09/26/2017 12:34 PM

Comments: