

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161771, Building Permit - Commercial

Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, September 26, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS:
SOUTH STAIRWELL:

BASEMENT: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER
PRE-ROCK ONLY;

1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; **[2ND LAYER
INCLUDING PRE-ROCK;**

2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; **[2ND LAYER
PRE-ROCK ONLY;**

NORTH STAIRWELL:

1ST FLOOR: **[2ND LAYER INCLUDING PRE-ROCK;**

2ND FLOOR: **[2ND LAYER PRE-ROCK ONLY;**

Partial Correction

2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT
ELEVATOR:

BASEMENT: 1ST LAYER; 2ND LAYER

1ST FLOOR: 1ST LAYER; **[2ND LAYER;**

2ND FLOOR: 1ST LAYER; **[2ND LAYER;**

Comments: