

Inspection Summary

Permit #: PRCOM20172339, Building Permit - Commercial
Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Wednesday, September 27, 2017
Partial Correction 1 Misc	EAST 1 HOUR WALL DIVIDING THIS SPACE FROM ADJOINING SPACE: PLAN CALLS FOR 5/8THS X GYP ON EACH SIDE. WEST SIDE OF WALL LAYER IS APPROVED. EAST SIDE OF WALL YET TO BE INSTALLED.		

Comments: