

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161619, Public Works Infrastructure Permit - Commercial
The Summit Church (NW Ashurst Dr. & NW Edgewood Dr.) Sanitary Sewer (offsite)
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Street - Surface Course	Steve Robbins	Passed	Wednesday, September 27, 2017

Corrective Action Required
1

DEI-Sanitary Sewer Construction Inspection	Steve Robbins	Passed	Wednesday, September 27, 2017
---	---------------	--------	-------------------------------------

Informational

1 The camera test has passed and the sag has been corrected. The mandrel passed and all tests have been completed. The sanitary has been completed. Steve Robbins 09/27/2017 2:23 PM

Comments: